WINDCREST AVCOM auto dialler programming University of Reading lifts

Message required

Alarm <u>LFT 0000</u> Security please PRESS the star key after the tone and zero to complete the call.

Programmer Settings

UNIT Type 1 for EN1, 3 for EN3, 4 for EN4

2 Lift Car COPs NO

Evac System? Yes (If Evacuation System is there)/ No (Without Evac

System)

Landing Spks? 01-24 (Do not count the Master Switching panel. Key in

two digit format. i.e. if there is One Evac Panel and Two

Landing Speakers, Key in 02.) This option will be skipped

automatically if the Evac System is programmed to No.

CB Hotline NO

1st Number: 6300

2nd Number: 6300

3rd Number: 7799

4th Number: 6300

SP Bit Set 1, 3, 5 & 6 to be set NO

Auto-Test Calls?: YES

Test – Call Hours: 70

5th Number: 8285

Auto-Pictogram?: NO

Ignore DTMF?: NO

RPA number: 8284

Call duration: 2

Instant Trigger? YES

AlarmPush N/C? NO (If the Alarm Push Contacts are Normally Closed,

Press Yes.)

AutoJump Next? Yes

Lift Number:- Use key 2 & 8 to Scroll to 1 and Press Enter

ID Message Type:- 1 (For Recorded Message as ID Message)

Record New? (If recording of the Message is not required Press Enter to go to next menu)

To Record the Message:- (Identify whether there is Microphone or Not on the Board)

If the board doesn't have the Microphone,

- 1) Connect the telephone handset to the AVCOM Board, Pick Up the handset.
- 2) Press 1 on the Programmer. start recording through Handset, Record the Message by speaking on the handset until the programmer goes back to Record New?.
- 3) To listen to the Recorded Message in the Lift Car/Handset connected, Press 2 on the programmer. At the end of the Message Programmer will show "Record New?"
- 4) If the message was Recorded correctly, Press "ENTER", if re-recording is required follow the steps from 1.

If the board has Microphone:-

- 1) Press 1 on the programmer to start recording via speaking to the Board Microphone until the programmer shows "Record New?".
- 2) To listen to the Recorded Message in the Lift Car/Handset connected, Press 2 on the programmer. At the end of the Message Programmer will show "Record New?"
- 3) If the message was Recorded correctly, Press "ENTER", if re-recording is required follow the steps from 1.

Voice Identify: YES
Have U finished: YES

Windcrest ID - - - - 0177 (Commissioning Engineer to complete and pass back to FMD to allow programming onto monitoring software.)

Telephone No of Auto dialler line:

Have you complete the EN81 test call procedure YES/NO and has it been confirmed YES/NO

Windcrest Central station EN81-28 test call procedure.

Connect up the programmer, and get in the "System Ready" screen. (ie power down and up again if you have to).

Press [3] to go into the TEST mode.

Press [6], [#] CANCEL, [#] CANCEL button.

This will effectively set all the internal counters to zero and make an attempt to call the central Station.

NB: This test MUST be carried out prior to acceptance of the lift at handover. Please call Chris Smith or Roberta Windmill on 0118 378 6278 to check the signal has been received. You will need to state the Windcrest ID number above to request confirmation.

A copy of this record sheet MUST be placed in the operating manual.